



NOTA:

- cutia de acces la firul trasor se va monta in afara carosabilului, in trotuare sau spatii verzi
- lungimea capatului firului trasor in cutia de accs va fi de min 20cm
- dupa fixarea firelor trasoare in conector, se va strange conectorul

INSTALATOR AUTORIZAT PROIECTARE

ing. Avarvarei Vasilica

aut. ANRE tip PGD 109200934/18.11.2020 valabila pana la data 17.11.2025

format A4 210x297mm

SC NECESAR PROD SRL J 1996000153097/2025 b-dul Dorobantilor, nr. 669, loc. Braila tel. 0239617563; e-mail: necesar_braila@yahoo.com aut. ANRE tip PDSB nr. 24176 valabila pana la 14.04.2030			EXTINDERE SISTEM DE DISTRIBUTIE GAZE NATURALE IN LOCALITATEA CAZASU Amplasament: loc. Cazasu, com. Cazasu, jud. Braila Beneficiar: COMUNA CAZASU		Proiect 48/2024 faza PT+DDE
PROIECTAT	ing. Avarvarei Vasilica		SCARA	DETALIU CUTIE ACCES LA FIR TRASOR; DETALIU IMBINARE FIR TRASOR	Plansa G80
DESENAT	ing. Avarvarei Vasilica		%		
APROBAT	ing. Murgoci Marian		DATA: 02.05.2025		