

**LISTA APARATAJ DBS1  
LEA 110 kV BACAU SUD 1**

**SC THERMOENERGY GROUP SA BACAU**  
Statia 110 kV CET  
**Dulap protectii LEA 110kV Bacau Sud 1**

**Lista aparataj**

Simbol	Denumire	Cod produs	Fabricant (Furnizor)	Cant	Observatii
N601	Terminal de protectie (de baza)	7SL86-DAAA-AA0-0AAAA0-AN0111-12111A-FBA000-000AC0-CB1BA1-CG0, P1C274739	SIEMENS	1	
N602	Terminal de protectie (de rezerva)	7SL86-DAAA-AA0-0AAAA0-AN0111-12111A-FBA000-000AC0-CB1BA1-CG0, P1C274739	SIEMENS	1	
X641,X642	Test switch	7XG2220-2AA00-0AA0	SIEMENS	2	
K921, K922	Releu supraveghere circuit de declansare	7PA3042-1AA00-1	SIEMENS	2	
F191	MCB 1P+N, In=4A, C, Un=230VAC			1	
F192	MCB 1P+N, In=6A, Un=230VAC			1	
F151,F161	MCB 2P, In=6A, Un=220VDC, 1NI+1ND			2	
F152,F162	MCB 2P, In=10A, Un=220VDC, 1NI+1ND			2	
K131,K132	Contactator Uc=220Vcc, 5CO	DILR-22G	EATON	2	
K151,K152,K153,K155,K181	Releu intermediar Uc=220Vcc, 4CO	56.34.9220.0040	FINDER	5	
K161,K162,K163,K165, K182	Releu intermediar Uc=220Vcc, 4CO	56.34.9220.0040	FINDER	5	
X511	DCD 1A		Relee Medias	1	
CR1	CR comanda locala		EATON	1	
CR2	CR verificare CS prin TNP1/ TNP2		EATON	1	
E100	termostat			1	
E101	Rez incalzire P=60W			1	
Z201	Door Switch			1	
E151	Lampa			1	
X011	priza monofazata, 16A, 2P+N			1	