

**LISTA APARATAJ DBS2
LEA 110 kV BACAU SUD 2**

SC THERMOENERGY GROUP SA BACAU
Statia 110 kV CET
Dulap protectii LEA 110kV Bacau Sud 2

Lista aparataj

| Simbol | Denumire | Cod produs | Fabricant (Furnizor) | Cant | Observatii |
|---------------------------|--|---|-------------------------|------|------------|
| N601 | Terminal de protectie (de baza) | 7SL86-DAAA-AA0-0AAAA0-AN0111-12111A-FBA000-000AC0-CB1BA1-CG0, P1C274739 | SIEMENS | 1 | |
| N602 | Terminal de protectie (de rezerva) | 7SL86-DAAA-AA0-0AAAA0-AN0111-12111A-FBA000-000AC0-CB1BA1-CG0, P1C274739 | SIEMENS | 1 | |
| X641,X642 | Test switch | 7XG2220-2AA00-0AA0 | SIEMENS | 2 | |
| K921, K922 | Releu supraveghere circuit de declansare | 7PA3042-1AA00-1 | SIEMENS | 2 | |
| | | | | | |
| F191 | MCB 1P+N, In=4A, C, Un=230VAC | | | 1 | |
| F192 | MCB 1P+N, In=6A, Un=230VAC | | | 1 | |
| F151,F161 | MCB 2P, In=6A, Un=220VDC, 1NI+1ND | | | 2 | |
| F152,F162 | MCB 2P, In=10A, Un=220VDC, 1NI+1ND | | | 2 | |
| | | | | | |
| | | | | | |
| K131,K132 | Contactor Uc=220Vcc, 5CO | DILR-22G | EATON | 2 | |
| K151,K152,K153,K155,K181 | Releu intermediar Uc=220Vcc, 4CO | 56.34.9220.0040 | FINDER | 5 | |
| K161,K162,K163,K165, K182 | Releu intermediar Uc=220Vcc, 4CO | 56.34.9220.0040 | FINDER | 5 | |
| | | | | | |
| X511 | DCD 1A | | Relee Medias | 1 | |
| | | | | | |
| CR1 | CR comanda locala | | EATON | 1 | |
| CR2 | CR verificare CS prin TNP1/ TNP2 | | EATON | 1 | |
| | | | | | |
| E100 | termostat | | | 1 | |
| E101 | Rez incalzire P=60W | | | 1 | |
| Z201 | Door Switch | | | 1 | |
| E151 | Lampa | | | 1 | |
| X011 | priza monofazata, 16A, 2P+N | | | 1 | |