



TABEL DE FURNITURI

Marca	Denumirea piesei	Semne conv.	Diametru (mm)	
			110-125	160-400
1	Teu redus la 90° PEID PE 100, SDR = 17, Pn 10 bar		110/90 125/90	160/110 200 /110 225/110 250/110 315/110 400/225
2	Reductie de polietilena PEID PE 100 SDR=17, Pn 10 bar pentru apa potabila		-	225/110
3	Tuburi de polietilena PEID PE 100 SDR=17, Pn 10 bar pentru apa potabila		90	110
4	Adaptor de flansa PEID PE 100 Pn 10 bar, inclusiv flansa aditionala OL Zn		90	110
5	Hidrant supratcran de incendiu		80	100

Denumirea piesei	Hidrant supratcran	
	DN80mm	DN100mm
Racord fix A = racord fix frontal B = racord fix lateral	2xB (DN3")	1xA (DN4") 2xB (DN3")

Rev	Nume	Ver	Aprb	Data	Descriere
-----	------	-----	------	------	-----------

Autoritatea contractanta: S.C.AQUACARAS S.A. CARAS SEVERIN					
 Adresa: P-ta Republicii, nr. 7, Resita Jud. Caras Severin Tel.: +40 255 212 458 Fax: +40 255 214 421 E-mail: office@aquacaras.ro					

Proiectant: Consortiu S.C Eptisa Romania S.R.L. si Eptisa Servicios de Ingenieria S.L.					
Sos. Dudesti-Pantelimon nr. 42, RAMS center, et. 5, corp A, sector 3, Bucuresti Tel: +40 21 301 14 70 Fax: +40 21 301 14 80 www.eptisa.com					

Proiect: MODERNIZAREA INFRASTRUCTURII DE APA SI APA UZATA IN JUDETUL CARAS SEVERIN - AGLOMERAREA RESITA					
Plansa:					

Detaliu tip
Montaj hidrant supratcran

Desenat:	Ing. V. Badan		Data: Aprilie 2013
Verificat:	Ing. C. Stoica		Data: Aprilie 2013
Aprobat:	Ing. D. Spiridon		Data: Aprilie 2013

Plansa nr.	Revizia
CS-RE-PT/DA-A-M-01	0