

Marca	ø	Buc	Lungime	OB 37		PC52				
				ø 6	ø 10	ø 8	ø 10	ø 12	ø 18	ø 20
1	10	10	3,40				34,00			
2	10	20	2,90				58,00			
3	10	10	3,35				33,50			
4	10	72	1,35				97,20			
5	10	20	3,20				64,00			
6	10	40	1,80				72,00			
7	6	34	0,60	20,40						
8	6	22	0,30	6,60						
9	10	8	0,85		6,80					
10	20	6	2,00							12,00
11	10	16	1,50				24,00			
12	10	4	2,40				9,60			
13	10	4	2,30				9,20			
14	18	12	2,00						24,00	
15	18	4	1,60						6,40	
16	10	24	Lm=0,9				21,60			
17	8	18	0,70			12,60				
18	8	14	0,65			9,10				
19	12	2	3,60					7,20		
20	10	5	0,85		4,25					
21	10	4	1,05		4,20					
22	12	16	1,60					25,60		
23	12	4	1,35					5,40		
m/ø				27,00	15,25	21,70	423,10	38,20	30,40	12,00
kg/ml				0,222	0,617	0,395	0,617	0,888	1,998	2,460
kg/ø				5,99	9,41	8,57	261,05	33,92	60,74	29,53
TOTAL				15		394				

- | | |
|-----------------|------|
| -radier | 45mm |
| -pereti | 40mm |
| -placa interior | 20mm |
| exterior | 30mm |

-Zona superioara a caminului se va betona pana la cota 0.00(cota finita drum), daca partea carosabila nu este din asfalt.

-Capacul va fi carosabil cu rama patrata, clasa D 400.


-Dimensiunile parțiale ale armaturilor sunt cotate la interior.

-Prezenta plansa se va citi impreuna cu plansele de

instalatii hidraulice.

BETON DE EGALIZARE
BETON ARMAT
OTEL BETON

C8/10,X0,Dmax 32,S3,CEM II B-M (S-LL) 32.5 R
C 25/30,XC4,XF3,C10.2,Dmax 22,S3,P4,CEM II/A-S 32.5R
OB 37, PC 52



DN	Bara marca a		Bara marca b	
mm				
90/110	22	1.60	23	1.35

Rev	Nume	Ver	Aprb	Data	Descriere

Autoritatea contractanta: **S.C.AQUACARAS S.A. CARAS SEVERIN**



Adresa: P-ta Republicii, nr. 7, Resita
Jud. Caras Severin
Tel.: +40 255 212 458
Fax.: +40 255 214 421
E-mail: office@aquacaras.ro

Proiectant:

Consortiu S.C Eptisa Romania
S.R.L. si Eptisa Servicios de Ingeniería S.L.
 Șos. Dudeștii-Pantelimon nr. 42, RAMS center, et. 5, corp A,
 sector 3, București
 Tel: + 40 21 301 14 70
 Fax: + 40 21 301 14 80
www.eptisa.com



Project:

MODERNIZAREA INFRASTRUCTURII DE

APA SI APA UZATA IN JUDETUL

CARAS SEVERIN - AGLOMERAREA RESITA

Plansa:

Retele apa
Camin tip 1-Plan Armare

Desenat: Ing. B. Paraschiv Data: Aprilie 2013

Verificat: Ing. M. Serbanoiu Data: Aprilie 2013

Aprobat: Ing. D. Spiridon Data: Aprilie 2013

Plansa nr.

CS-RE-PT/DA-A-R-1.2

Revizia

0